

How to Read Your Drinking Water Test Results



359 SOUTH PARK DR
COLCHESTER, VT 05
(802) 338-4724 or (800) 660-99
www.healthvermont.g

This unique number is used to identify your test results.

Results Report

State Health Dept # : 18-IC-03319
Report Status : Final
Date Report Released : 07/13/2018

Report To
ATTN OF
Address



WSID

Account Name



Date Received 07/09/2018

Time Received 10:15

A

The **limit** is the maximum amount of a contaminant that is allowed in your drinking water based on federal or state standards. The unit of measure is the same as for the final result (mg/L). If the **final result** is higher than the **limit**, consider treating your water to reduce or remove the chemical. You can find treatment options when you click on the contaminant at www.healthvermont.gov/water-contaminants

Sample Desc. KIT C
Collection Date 07/09/2018
Collection Time 06:30
S
S
S
T
S

The **final result** is how much of a contaminant is in your drinking water.

Units are measured in milligrams per liter (mg/L).

Test	Anions	Date/Time	07/09/2018 13:43
		Test Method	EPA 300.0
Analyte	Final Result	Units	Limit
Fluoride	4.37	mg/L	4.0 MCL
Chloride	28	mg/L	250 SMCL
Nitrite as N	<0.10	mg/L	1.0 MCL
Nitrate as N	<0.50	mg/L	10.0 MCL

** See below for Nitrate and/or Nitrite.

Test	Hardness (EDTA)	Date/Time of Analysis	07/09/2018
		Test Method	SM 2340 C
Analyte	Final Result	Units	Limit
Hardness	< 5 mg	mg/L	*

The symbol "<" means "less than." Here, the nitrate level is less than 0.50.

Test	Iron by Flame AA	Date/Time of Analysis	07/10/2018 11:50
		Test Method	SM 3111 (B)
Analyte	Final Result	Units	Limit
Iron	<0.10	mg/L	0.3 SMCL