

**Summary of Lead in Drinking Water Results for Johnson Elementary School<sup>1</sup>**

<b>Sample Location</b>	<b>First-Draw Result<sup>2</sup> ppb</b>	<b>Flush Result<sup>3</sup> ppb</b>
106 Kitchen South	1	<1
106 Kitchen West 1	2	<1
106 Kitchen West 2	2	<1
106 Kitchen West 3	<1	<1
107 Music	4	<1
201 Fountain	<1	
201 Sink	<1	<1
202 Fountain	<1	
202 Sink	<1	<1
203 Fountain	1	
203 Sink	<1	<1
206 Fountain	<1	
206 Sink	<1	<1
207 Fountain	<1	
207 Sink	<1	<1
208 Nurse	1	<1
210 Principal	3	2
214 Staff Fridge	<1	<1
214 Staff Sink	<1	<1
301 Fountain	<1	
301 Sink	<1	<1
302 Fountain	<1	
302 Sink	<1	<1
303 Fountain	<1	
303 Sink	<1	<1
304 Fountain	<1	
304 Sink	<1	<1
305 Fountain	<1	
305 Sink	<1	<1
306 Fountain	<1	
306 Sink	<1	<1
307 Fountain	<1	
307 Sink	<1	<1
308 Fountain	<1	

Sample Location	First-Draw Result <sup>2</sup> ppb	Flush Result <sup>3</sup> ppb
308 Sink	1	<1
310 Fountain	<1	
310 Sink	<1	<1
311 Fountain	<1	
311 Sink	<1	<1
402 Fountain	<1	
402 Sink	<1	<1
404 Fountain	<1	
404 Sink	<1	<1
406 Fountain	<1	
406 Sink	<1	<1
407 Fountain	<1	
407 Sink	8	<1
Bottle Filler Fountain	<1	<1
Bottle Filler Sensor	<1	
Main Entrance High	<1	<1
Main Entrance Low	1	

**Notes:**

1. The Environmental Protection Agency’s action level for lead in public drinking water is 15 parts per billion (ppb). The Vermont Health Advisory for lead in drinking water is 1 ppb.
2. A first draw sample collects the first water to come out of the tap after a period of inactivity, typically 8-18 hours. A high first draw result may indicate that faucets and fixtures are the likely source of lead.
3. A flush sample is taken after running cold water for 30 seconds, which tests water further upstream in the plumbing. A high flush result may indicate that plumbing is the likely source of lead.