

Summary of Lead in Drinking Water Results for St. Johnsbury School¹

Sample Location	First-Draw Result² ppb	Flush Result³ ppb
10 Fountain	<1	
10 Sink	<1	<1
101 Fountain	<1	
101 Sink	1	<1
103 Sink	<1	<1
104 Fountain	<1	
104 Sink	<1	<1
106 Fountain	<1	
106 Sink	<1	<1
107 Fountain	<1	
107 Sink	1	<1
108 Fountain	<1	
108 Sink	1	<1
109 Fountain	<1	
109 Sink	<1	<1
110 Fountain	<1	
110 Sink	<1	<1
111 Fountain	<1	
111 Sink	<1	<1
112 Fountain	<1	
112 Sink	<1	<1
19 Sink	1	<1
1st Floor Filler	<1	<1
1st Floor Fountain	<1	
1st Floor Teachers Room S Sink	<1	<1
1st Floor Teachers Room W Sink	2	<1
201 Fountain	<1	
201 Sink	2	<1
204 Sink	<1	<1
205 Fountain	<1	
205 Sink	<1	<1
207 Fountain	<1	
207 Sink	1	<1
208 Fountain	<1	
208 Sink	<1	<1
209 Fountain	<1	

Sample Location	First-Draw Result ² ppb	Flush Result ³ ppb
209 Sink	<1	<1
210 Fountain	<1	
210 Sink	<1	<1
211 Fountain	<1	
211 Sink	<1	<1
212 Fountain	<1	
212 Sink	<1	<1
213 Fountain	2	
213 Sink	<1	<1
22 Fountain	1	
22 Sink	1	<1
24 Sink L	1	<1
24 Sink R	<1	
26 Sink	2	<1
28 Sink	<1	<1
2nd Gym Fountain L	<1	<1
2nd Gym Fountain R	<1	
2nd Lobby Fountain L		<1
2nd Lobby Fountain R	<1	
2nd Teachers Room W Sink	2	<1
30 Sink	<1	<1
301 Sink L	1	<1
301 Sink R	2	
302 Sink	<1	<1
303 Fountain	<1	
303 Sink	2	<1
304 Fountain	<1	
304 Sink	<1	<1
305 Fountain	<1	
305 Sink	<1	<1
306 Fountain	<1	
306 Sink	4	<1
307 Fountain	<1	
307 Sink	<1	<1
308 Fountain	<1	
308 Sink	<1	<1
309 Fountain	<1	
309 Sink	1	<1
31 A Fountain	<1	

Sample Location	First-Draw Result² ppb	Flush Result³ ppb
31 A Sink	<1	<1
310 Fountain	<1	
310 Sink	<1	<1
33 Fountain	<1	
33 Sink	3	<1
37 Bathroom Sink	<1	<1
3rd Floor Filler	<1	
3rd Floor Fountain	<1	<1
3rd Floor Teachers Room W Sink	1	<1
4 Fountain	<1	
4 Sink	<1	<1
A Fountain	<1	
A Sink	<1	<1
B Fountain	<1	
B Sink	<1	<1
Boys Locker Room Fountain	<1	<1
C Fountain	<1	
C Sink	<1	<1
Cafe Fountain L	<1	<1
Cafe Fountain R	<1	
D Fountain	<1	
D Sink	<1	<1
E Fountain	<1	
E Sink	<1	<1
F Fountain	<1	
F Sink	<1	<1
Girls Locker Room Fountain	<1	<1
Kitchen Prep Sink L	3	<1
Kitchen Prep Sink R	<1	
Lobby Fountain L	<1	<1
Lobby Fountain R	<1	
Maintenance Sink	<1	<1
Pre K Fountain L	<1	<1
Pre K Fountain R	<1	
Pre K Teachers Room Sink	<1	<1
S1 Sink 1	<1	<1
S1 Sink 2	<1	<1
S1 Sink 3	3	
S10 Fountain	<1	

Sample Location	First-Draw Result ² ppb	Flush Result ³ ppb
S10 Sink	<1	<1
S11 Fountain	<1	
S11 Sink	<1	<1
S2 Fountain	<1	
S2 Sink	<1	<1
S3 Fountain	<1	
S3 Sink	<1	<1
S4 Fountain	<1	
S4 Sink	<1	<1
S5 Fountain	<1	
S5 Sink	<1	<1
S6 Fountain	<1	
S6 Sink	<1	<1
S7 Fountain	<1	
S7 Sink	<1	<1
S8 Fountain	<1	
S8 Sink	<1	<1
S9 Fountain	<1	
S9 Sink	<1	<1

Notes:

1. The Environmental Protection Agency's action level for lead in public drinking water is 15 parts per billion (ppb). The Vermont Health Advisory for lead in drinking water is 1 ppb.
2. A first draw sample collects the first water to come out of the tap after a period of inactivity, typically 8-18 hours. A high first draw result may indicate that faucets and fixtures are the likely source of lead.
3. A flush sample is taken after running cold water for 30 seconds, which tests water further upstream in the plumbing. A high flush result may indicate that plumbing is the likely source of lead.