

Summary of Lead in Drinking Water Results for Thatcher Brook Primary School¹

Sample Location	First-Draw Result² ppb	Flush Result³ ppb
100 Fountain	<1	
100 Sink	<1	<1
101 Fountain	<1	
101 Sink	<1	<1
102 Fountain	<1	
102 Sink	<1	<1
103 Fountain	<1	
103 Sink	<1	<1
110 Fountain	<1	
110 Sink	<1	<1
119 Hall Fountain	<1	
119 Hall Sink	<1	<1
121 Fountain	<1	
121 Sink	<1	<1
134 Sink	<1	<1
139 2 Bay Sink	<1	<1
139 3 Bay Sink	<1	2
139 Bottle Fill	<1	
139 Cooler	<1	<1
139 Single Bay Sink	3	<1
200 Fountain	<1	
200 Sink	<1	<1
201 Fountain	<1	
201 Sink	<1	<1
202 Fountain	<1	
202 Sink	<1	<1
203 Fountain	<1	
203 Sink	<1	<1
216 Fountain	<1	
216 Hall	<1	<1
216 Sink	<1	<1
217 Fountain	<1	
217 Sink	<1	<1
218 Fountain	<1	
218 Sink	<1	<1

Sample Location	First-Draw Result ² ppb	Flush Result ³ ppb
234 Bottle Filler	<1	
234 Fountain	<1	<1
235 Fountain	<1	
235 Sink	<1	<1
236 Fountain	<1	
236 Sink	<1	<1
237 Fountain	<1	
237 Sink	<1	<1
238 Fountain	<1	
238 Sink	<1	<1
300 Fountain	<1	
300 Sink	<1	<1
301 Fountain	<1	
301 Sink	<1	<1
302 Fountain	<1	
302 Sink	<1	<1
303 Fountain	<1	
303 Sink	<1	<1
310 Fountain	<1	
310 Sink	<1	<1
311 Deep Sink	<1	
311 Fountain	<1	
311 Sink	<1	<1
314 Fountain	<1	
314 Sink	<1	<1
330 Fountain	<1	
330 Sink	<1	<1
331 Fountain	<1	
331 Sink	<1	<1
333 Fountain	<1	
333 Sink	<1	<1
334 Fountain	<1	
334 Sink	<1	<1
Ctr 3rd Floor Bottle Fill	<1	
Ctr Bld 3rd Floor Cooler	<1	<1
S Bld 3rd Floor Fountain	4	1
S. Bld 2nd Floor Cooler	<1	<1

Notes:

1. The Environmental Protection Agency's action level for lead in public drinking water is 15 parts per billion (ppb). The Vermont Health Advisory for lead in drinking water is 1 ppb.
2. A first draw sample collects the first water to come out of the tap after a period of inactivity, typically 8-18 hours. A high first draw result may indicate that faucets and fixtures are the likely source of lead.
3. A flush sample is taken after running cold water for 30 seconds, which tests water further upstream in the plumbing. A high flush result may indicate that plumbing is the likely source of lead.